



# TEST SUMMARY


**Filter:** **IN-LINE 3000 (CKG-Super Lite W)**

**Manufactured by:** CF-Industrial BV, The Netherlands

Is independently tested by SGS Nederland BV.

*Project number: EZEM/2017-02/00006*

Flow (m <sup>3</sup> (actual at 25°C)/h)	Pressure drop (Pa)
333	19
713	66
1283	190
1608	290
1732	339



Date: September 25, 2017

Approved by:

**J. Boot**

**Environment, Health and Safety**

**Operational Manager Air Monitoring**

SGS Nederland B.V. is an ISO17025 certified testing laboratory.

Leemansweg 51 P.O. Box 5252 6802 EG Arnhem t +31(0)26-3844 500 www.sgs.com

